



# Compliance Statement

## Screened Category 7 ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable

**Solarix Identification P/N SXKD-7-SSTP-LS0H**

**Category 7, Individual Foil and Overall Braid Screened  
100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Cable**

**INTELEK spol. s r.o.  
Vlarska 22  
627 00 Brno, Czech Republic**

***Compliance Statement No. 110530E***

*This Screened ISO/IEC, EN & Enhanced ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 7 performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011 and 2<sup>nd</sup> edition IEC Cable Standard 61156-5, incl. amendment 1, the Category 6<sub>A</sub> requirements of ANSI/TIA Generic Cabling Standard 568-C.2 and the requirements of CENELEC Cable Standard EN 50288-4-1:2013. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment.1 and IEC 60754-2 The cable has EMC Performance Rating 9. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 17<sup>th</sup> December 2013

A handwritten signature in blue ink, appearing to read "Ole Lambertsen".

Ole Lambertsen  
Test Responsible

Hoersholm, 17<sup>th</sup> December 2013

A handwritten signature in blue ink, appearing to read "Poul Villien".

Poul Villien  
Coordinating Manager